

## THE AUTHORITY ON SUSTAINABLE BUILDING



## all joints must be sealed removable access lid at ground level must prevent ingress of surface water concrete top concrete pipe internal diameter 1 m min. ladder rungs as necessary greater than 1 m (cover level inspection point to drain invert) flexible joint within 225 mm of concrete surround concrete fill to inspection point level 150 mm concrete base min. 150 mm concrete surround to drains and chamber flexible joint within 225 mm of concrete surround

## Access chamber with inspection point

© BRANZ 2009